




Flow Switch Adaptors



With the emphasis on flexibility and ease of installation, many building design projects are now focusing on products and services that can adapt to changing legislation, energy efficiency and the ever changing needs of the client. Flexibility is important as requirements can change and the ability to gain additional switch outputs quickly to adapt to these changes are seen as an advantage.

Flow Switch Adaptors

Product Range

Flow Switch Adaptors


CT2300

250V~ 20A 4 Pole Click Flow Switch Adaptor


(With Pre-Wired Permanent Live, Earth & Neutral Links)



CT2300



Product Dimensional Drawings (mm)



V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454

E-mail: sales@scolmore.com, technical@scolmore.com

Facsimile: 01827 63362

Website: www.scolmore.com

Flow Switch Adaptors

Product Range

Flow Switch Adaptors


CT1300

250V~ 20A 3 Pole Click Flow Switch Adaptor


(With Pre-Wired Earth & Neutral Links)



CT1300



Product Dimensional Drawings (mm)



V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454

E-mail: sales@scolmore.com, technical@scolmore.com

Facsimile: 01827 63362

Website: www.scolmore.com

Flow Switch Adaptors

Technical Specification

Flow Switch Adaptors

Material Composition	Cover: Polycarbonate
	Base: Nylon PA66
	Terminals: HPb59-1 (CU 59%) Silver Plated
	Terminal Screws: Steel and Yellow Passivated
Voltage	250V~ 50Hz
Current Rating	20A Max
Terminal Conductor Size	Up to 4 x 1.00mm ² T&E
Compatible Products	3 or 4 Pole Male & Female Flow Connectors
Input / Output	1 Male Input (Supply) to receive Female Connector
	1 Female Output to receive Male Connector
Pre Wired Links	2.5mm ² Permanent Live, Earth & Neutral Links (4 Pole)
	2.5mm ² Earth & Neutral Links (3 Pole)
Warranty	10 Years
IP Rating	IP20
Operational Temperature	-5° to +40°C
Standards	IEC EN 61535 : 2009 + A1: 2013 + C1: 2014
	BS 5733 : 2010 + A1 : 2014
	BS 8488 : 2009 + A1 : 2010

Errors & Omissions excluded. Specification is subject to change without notice. Pre-Fabricated wiring systems manufactured to BS 8488 by other manufacturers may not be compatible or safely inter-connectable with this system. Any dangerous compatibility between different manufacturers installation coupler systems is not automatically prevented by compliance with IEC 61535.

V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454

E-mail: sales@scolmore.com, technical@scolmore.com

Facsimile: 01827 63362

Website: www.scolmore.com

EU DECLARATION OF CONFORMITY

Issuer Name: Scolmore International Ltd

Issuer Address: 1, Scolmore Park, Landsberg, Lichfield Road Industrial Estate,
Tamworth, Staffordshire B79 7XB UK

Issuer Contact Details: Tel: +44 (0) 1827 63454
Fax: +44 (0) 1827 63362
Email: sales@scolmore.com
Website: www.scolmore.com

Object(s) Of Declaration: CLICK FLOW

Group: Inline Switch Adaptor

Model No.(s): CT1300,CT2300

The object of the declaration is in conformity with the relevant union harmonisation legislation:

2014/35/EU Low Voltage Directive
2011/65/EU RoHS Directive
2015/863/EU RoHS 2 Directive
1907/2006/EU REACH Directive

All products contained within the aforementioned comply with the relevant standards and requirements listed below.

BS 8488 : 2009+ A1 :2010
IEC EN 61535: 2009 + A1: 2013 + C1: 2014
BS 5733: 2010 + A1: 2014

I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications.

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001: 2015.

This declaration has been issued under the sole responsibility of the manufacturer, signed at, for and on behalf of:
Scolmore International Limited.



Karl Rawlins - Senior Technical Support Engineer

Date: 24th January 2019